

STATE OF WISCONSIN
WAUPACA COUNTY
TOWN OF WYOMING

MINIMUM PRIVATE DRIVEWAY REQUIREMENTS ORDINANCE

01-2013

WHEREAS, it is in the public interest for the Town of Wyoming, Waupaca County, Wisconsin to establish minimum driveway standards and/or requirements to accommodate fire department and emergency vehicle personnel access for fire protection and emergencies.

NOW THEREFORE IT IS HEREBY ORDAINED: By the Town board of supervisors of the Town of Wyoming, Waupaca County, as follows:

- A. All previous Town of Wyoming Minimum Private Driveway Requirements and Ordinances relating thereto, are hereby repealed and recreated as follows:
- B. Driveways must have a minimum of (20') twenty feet width. Any residential driveway bed must be covered with a minimum of 6 inches of gravel or crushed rock, of road construction surface grade.
- C. Tree limbs and wires shall be at least twenty (20') feet above the base of the road. Tree limbs must be trimmed on each side of the driveway/road to prevent breakage of equipment and damage to equipment.
- D. If fire department and/or emergency equipment are required to cross creeks or rivers- there must be an approved bridge (approved by Marion Fire Department) to handle the weight of the equipment.
- E. At the dead end of the driveway, a turn-a-round of at least fifty (50') feet radius or some other method to allow vehicles to turn around shall be provided.
- F. If a culvert is required, there must be a minimum of one (1') foot of culvert on each end of the twenty (20') foot minimum driveway width.
- G. The driveway within the area of the public right-of-way shall slope away from the public road at a minimum 1% and a maximum of 5% to prevent erosion on the public road.

NOW THEREFORE, it is hereby ordained by the Town Board of supervisors of the Town of Wyoming, Waupaca County, that if the above requirements are not met by the landowner, Town of Wyoming will not be responsible for the fire and emergency protection of these properties.

TOWN OF WYOMING

By: Burton Brady
Burton Brady, Chairman

By: Jeremy Schoenike
Jeremy Schoenike, Supervisor

By: Margie Schmidt
Margie Schmidt, Supervisor

ATTEST:
Carol Myers
Carol Myers, Clerk

Adopted May 7, 2013